



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

www.rivcoeh.org

SUPPLEMENTAL REPORT TO SAN. FORM # _____ DATE 3-10-2020
SUBJECT Power Bowl PERMIT NO. 68826
ADDRESS 1185 Magnolia DISTRICT 51
INSPECTOR K. LORGE

REMARKS: During the routine inspection of an adjacently located food facility, observed the grease interceptor behind Power Bowl overflowing. Operator confirmed this to be their grease interceptor. Observed greasy water flowing out from around manhole cover. Operator instructed to immediately cease operation, stop use of water, and contact pumping service.

"Facility Closed" sign posted. Grade card removed

Once facility has pumped interceptor, restored a properly functioning wastewater system, contact this Department (951) 273-9140 for re-inspection to operate.

RECEIVED BY: