



## County of Riverside DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234

[www.rivcoeh.org](http://www.rivcoeh.org)

### INSPECTION REPORT

FACILITY NAME <b>Felipe's Cafe</b>					DATE 12/22/2021	TIME IN 3:30 PM	TIME OUT 4:15 PM
LOCATION 400 S El Cielo Rd Ste.A, Palm Springs, CA 92262						RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Felipe Sanchez					E-MAIL fesanchez7474@gmail.com		
PERMIT # PR0069078	EXPIRATION DATE: 12/31/2022	SERVICE Facility closure	FACILITY PHONE #: (760)774-4917	PE 3620	DISTRICT 0024	INSPECTOR NAME Darrel Balancier	

#### Inspector Observations:

#### Overall Inspection Comments

A follow-up inspection was conducted to verify that violations that resulted in the facility being downgraded have been corrected.

At start of the re-inspection the hot water was observed above 100 F at the hand sink but this hot water temperature could not be maintained after the dishwasher and 3 compartment sink were ran and set-up.

The hot water temperature was measured at 90 F.

The owners of the Restaurant voluntarily closed. Ensure no food preparation or utensil equipment cleaning occurs until verification of the restoration of hot water is verified by this Department.

A Facility close sign was posted on the front entry door to the restaurant. And "B" placard is still posted.

Contact this Department at (760)320-1048 once the hot water temperature is restored to all sinks and demand for it maintained at all times.

#### Signature

Signature not captured due to  
COVID 19 pandemic.

**Felipe Sanchez**  
Person in Charge  
12/22/2021

**Darrel Balancier**  
Environmental Health Specialist  
12/22/2021