



County of Riverside DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234

www.rivcoeh.org

INSPECTION REPORT

FACILITY NAME Dickey's Barbecue Pit						DATE 9/9/2022	TIME IN 3:00 PM	TIME OUT 5:00 PM
LOCATION 12620 Day St Ste.E, Moreno Valley, CA 92553							RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Pawanjot Kaur						E-MAIL pawan77@mail.com		
PERMIT # PR0085523	EXPIRATION DATE: 08/31/2023	SERVICE Facility closure	FACILITY PHONE #: (951)221-1947	PE 2620	DISTRICT 0001	INSPECTOR NAME Richard Conant		

Inspector Observations:

38. ADEQUATE VENTILATION & LIGHTING: DESIGNATED AREAS; USE

Violation Description: Mechanical exhaust ventilation shall be provided to remove toxic gases, heat, grease, vapors, and smoke. All areas of a food facility shall have sufficient ventilation to facilitate proper food storage and provide a reasonable condition of comfort for each employee. Toilet rooms shall be vented to the outside air by a screened openable window, an air shaft, or a light-switch activated exhaust fan. Adequate lighting shall be provided in all areas to facilitate cleaning and inspection. Light fixtures in areas where open food is stored, served, prepared, and where utensils are washed shall be of shatterproof construction or protected with light shields. (114149, 114149.1, 114149.2, 114149.3, 114252, 114252.1)

Violation Comments: Hood in facility not working. Operator placed a household fan on top of smoker and removed filters to try to direct smoke into canopy. Facility is filled with smoke, making it hard to see and breath. Facility closed until hood can be properly repaired.

Overall Inspection Comments

Complaint regarding heavy smoke inside facility with customer going to hospital for smoke inhalation. Upon investigation the following is noted.

Facility observed operating with heavy smoke filling the entire facility with my eyes burning from the smoke. observed gross negligence with removed exhaust hood filters with fan blowing grease laden exhaust into upper chambers of hood without filtration. It appears Hood not properly functioning. Facility closed

This is the second closure in the last 4-5 weeks due to same issue with removing hood filters. Gross negligence for upholding California standards of safety and health.


an office hearing is scheduled for tuesday 9/13/2022 at 9am at our location at 4065 county circle dr #104. Riverside Ca 92503. failure to attend will result in closure being sustained longer and possible further legal action. It is unlawful to re-open prior to approval from this department.

an air balance report will be required prior to re-opening which will be discussed during office hearing. City of Moreno Valley Fire Department will be required to sign off on approval for reopening as well- again, will be disucssed during office hearing.

Signature

Signature not captured due to
COVID 19 pandemic.

Noel
Person in Charge
09/09/2022



Richard Conant (Inspector)
Person in Charge
09/09/2022