



County of Riverside

DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234
www.rivcoeh.org

FACILITY NAME Original Pancake House - Temecula					DATE 8/28/2019	TIME IN 9:15 AM	TIME OUT 10:15 AM
LOCATION 41377 Margarita Rd #F101, Temecula, CA 92591						RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Majid Shojaee					E-MAIL tomajid@yahoo.com		
PERMIT # PR0008091	EXPIRATION DATE: 08/31/2020	SERVICE Facility closure	FACILITY PHONE #: (858)449-0292	PE 3621	DISTRICT 0042	INSPECTOR NAME Kristen Burnham	

Inspector Observations:

21. HOT AND COLD WATER AVAILABLE

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. Hot water of at least 120°F must be provided for facilities with unpackaged food or packaged potentially hazardous food. Handwashing facilities shall be equipped to provide warm water for at least 15 seconds. (113953(c), 114189, 114192 (a,d), 114192.1, 114195)

Inspector Comments: At the start of the routine inspection of this facility, it was observed that the water heaters are not functioning. A maximum of 80 °F was observed at the 3-compartment sink. Both tankless water heaters were showing an error code. The units were reset by the manager, but this did not result in restoration of hot water. All food preparation and warewashing activities were stopped. The manager stated hot water had been present earlier this morning. The facility is hereby closed due to a lack of hot water. A closure sign was posted at the front; do not remove this sign. Contact the inspector once the water heaters have been repaired and water of at least 120 °F is present. If the facility is observed to be operating in the future without hot water: the facility will be closed, a \$100 citation will be issued and an Administrative Hearing will be required prior to the facility being reopened. The routine inspection was stopped upon discovering the lack of hot water.

Signature

Kassandra Martinez
Person in Charge
08/28/2019

Kristen Burnham
Environmental Health Specialist
08/28/2019