



County of Riverside DEPARTMENT OF ENVIRONMENTAL HEALTH

For general information call: 1-888-722-4234
www.rivcoeh.org

FACILITY NAME Al-Karam Pakistni					DATE 10/28/2019	TIME IN 2:00 PM	TIME OUT 2:40 PM
LOCATION 3457 Arlington Ave, Riverside, CA 92506						RE-INSPECTION DATE Next Routine	
PERMIT HOLDER Raja M Ahmed					E-MAIL rajaadeel578@gmail.com		
PERMIT # PR0077032	EXPIRATION DATE: 04/30/2020	SERVICE Facility closure	FACILITY PHONE #: (951)742-5610	PE 3621	DISTRICT 0002	INSPECTOR NAME Emily Piehl	

Inspector Observations:

21. HOT AND COLD WATER AVAILABLE

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. Hot water of at least 120°F must be provided for facilities with unpackaged food or packaged potentially hazardous food. Handwashing facilities shall be equipped to provide warm water for at least 15 seconds. (113953(c), 114189, 114192 (a,d), 114192.1, 114195)

Inspector Comments: The purpose of this visit was to conduct a routine inspection. Upon arrival measured the hot water to be at 75F. Owner stated the water heater was in disrepair and had to order a part to fix it. No food preparation was observed during the inspection and only cleaning was being done. Facility is closed due to lack of hot water above 100F. Facility may not operate until hot water is restored and verified by someone from this department. Call Emily at 951-358-5172 once water heater is repaired. Facility is not approved to prepare food until reinspection.

Signature

Raja M. Ahmed

Raja
Person in Charge
10/28/2019

Emily Piehl

Emily Piehl
Environmental Health Specialist
10/28/2019